

CERTIFICATE OF TEST AND CONFORMITY

This is to certify the valves listed below have been tested in our facilities in Italy, according to the relevant standards and approved. The tests are carried out in order to confirm that the products are meeting the requirements of the purchase order and unless noted in all respects to the specification and drawings related thereto.

PRODUCT SPECIFICATION

Figure Number	Valve Specification	Valve Rating	Flange Specification
FLBGL-16	BS5154	PN16	TAPER THREAD BS21 (ISO 7)
Description			
FIG. FLBGL-16 BRONZE GLOBE VALVE RISING STEM PN16 RATED THREADED BONNET ALUMINIUM HANDWHEEL DISC (½" – 1¼") – DZR BRASS CW602N DISC (1½" - 2") – BRONZE CC491K			

Material Specification

Body	Stem	Bonnet
BRONZE CC491K	DZR BRASS CW602N	BRONZE CC491K

Test Results

Specification No. BS5154	Pressure bar	Fluid	Duration
Body	24	WATER	
Seat	17.6	WATER	

Agreed Concessions:

For and on behalf of
flowconME srl
 QA/QC Dept.

flowconME
 Porrettana 277, 40033 Casalecchio di Reno (BO), Italy